



- NOTES:
- SEALANT NOT SHOWN. CONSULT HARDEN FOR SEALANT PROCEDURES.
  - FRAME BOLT SIZE AND SPACING AS PER CERTIFIED DESIGN.
  - PLATE SUBFRAME SHOWN, TUBE SUBFRAMES AND OTHER MOUNTING OPTIONS AVAILABLE.
  - STANDARD 15 MINUTE FE/BR GLAZING SHOWN, OTHER OPTIONS AVAILABLE.
  - STANDARD INTERIOR AND EXTERIOR TRIM SHOWN, OTHER OPTIONS AVAILABLE.

A.F.F. = ABOVE FINISHED FLOOR  
 C.O. = CLEAR OPENING  
 CUST. = CUSTOMER  
 D.O. = DOOR OPENING  
 EXT. = EXTERIOR  
 F.F. = FINISHED FRAME  
 INT. = INTERIOR  
 L.C. = LOCATION  
 No. = NUMBER  
 P.O. = PURCHASE ORDER  
 QTY. = QUANTITY  
 R.O. = ROUGH OPENING  
 V.O. = VISION OPENING  
 W.O. = WORK ORDER

TOLERANCES:		<b>HARDEN ARCHITECTURAL          SECURITY PRODUCTS LLC.          LANCASTER, PA 17601</b>		
ANGULAR (DEG/MIN)	±0°30'			
LINEAR (FRAC)	±1/16	TITLE		
LINEAR (DEC)	.X ±.06 .XX ±.03 .XXX ±.015	WAFV-15R 15 MIN. FE/BR ALUM. WINDOW SLIP JOINT CAD DETAILS		
DRAWN BY:	DATE:	SIZE	DWG. NO.	REV.
CHECKED BY:	DATE:	WAFV-15R CAD-SJ		
ENGINEERED BY:	DATE:	SCALE	V.D. NO.	SHEET